ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

Ref.No.: BESCOM/CGM(P)/DGM(P)/AGM(P3)/BC-10/2024-25/8029

Telephone :080-22352704
E-mail: cgmproc@bescom.co.in

O/o The Chief General Manager (Ele),
Procurement Section,
2nd Floor, Corporate Office,
BESCOM, K.R. Circle,
Bengaluru–560001.

Date: 12 FEB 2025

AMENDMENT

Sub: Procurement of Vehicle Mounted Fully Automatic Underground Cable Fault Locating Equipment Suitable for Locating Fault as per Tender Specifications. (Capacity – 2000 Joules) to BRAZ & CTAZ Area, BESCOM– Reg.

Ref: BESCOM/2024-25/IND0102

*****

Tender was invited for Procurement of Procurement of Vehicle Mounted Fully Automatic Underground Cable Fault Locating Equipment Suitable for Locating Fault as per Tender Specifications. (Capacity – 2000 Joules) to BRAZ & CTAZ Area, BESCOM.

In this regard, some of the prospective Bidders have requested for amendment to the specifications. The same was placed before the management and was decided as follows:

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
1	Technical Specification clause 1.2	1 Scope: 1.2 All Functions should be controlled and monitored via integrated industrial PC running on user friendly base Operating System with suitable Anti Virus cyber security.	We use Linux OS, and this OS is not prone to virus and cyber-attack, please consider the need of antivirus as optional.	Tender condition prevails. Our specification has operating system in general, we have not specified name of the operating system.

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
2	Technical Specification clause 2.6 & 3.12	Industrial PC with user friendly manufacture System with UPS.	Please consider UPS as optional as data will not be lost even as we offer Linux OS even if PC shuts down due to power interruption.	Tender condition prevails.
3	Technical Specification clause 2.5	Cable Fault Location Guide. The Cable Fault Location Guide should be designed to guide operators through the cable fault location and testing process. Just by entering the most common cable parameters; such as nominal voltage, cable length and the available details from the manufacturer Cable Data base, the system should determine the correct test parameters and procedures which then only need the final confirmation for application of the operator.	Please consider this feature as optional as cable fault location is a man machine combination and software can't decide and guide user about fault location methods 100%.	Tender condition prevails.
4	Technical Specification clause 3.13	The suitable protection unit shall be provided to equipment in case of energized cable	As per safety regulations this practice is not valid and encouraged. User must take precaution and refrain connecting instrument to energized cable.	The suitable protection unit shall be provided to equipment.
5	Technical Specification clause 3.19	Warranty / Guarantee :	We confirm warranty period for all Megger items Warranty. For non megger items std OEM warranty will be considered. (like vehicle, DG set, tools,) will be as per the Manufacturer's warranty.	Tender Condition prevails.

Sl. No	Clause No	As Existing	Amendment as requested by the Prospective Bidders	Amendment issued
6	SECTION V SCHEDULE OF REQUIREMENT IND0102	Successful Tenderer shall deliver 05 (Five) Nos. of Vehicle Mounted Fully Automatic Underground Cable Fault Locating Equipment Suitable for Locating Fault as per Tender Specifications within Six months from the date of issue of Purchase Order.	Successful Tenderer shall deliver 06 (Six) Nos. Vehicle Mounted Fully Automatic Underground Cable Fault Locating Equipment Suitable for Locating Fault as per Tender Specifications within **Eight** months from the date of issue of Purchase Order.	Successful Tenderer shall deliver **06 (Six) Nos.** Vehicle Mounted Fully Automatic Underground Cable Fault Locating Equipment Suitable for Locating Fault as per Tender Specifications within **Six** months from the date of issue of Purchase Order.
7	Technical Specification clause 3.16	Fabrication of Cable Fault Locating. The registration of the vehicle shall be white board only if Diesel driven Vehicle with authorized modification certificate from RTO shall be produced along with the vehicle documents	As per the Karnataka existing RTO Norms Registration will be made. Should you require any further information /clarification, please do feel free to contact us. Thanking you in anticipation,	Tender Condition prevails. Will be decided at the time of issuing Purchase Order.

Approved by Managing Director, BESCOM

12/2

(Er.Shivaprakash.T.M)
Chief General Manager (Electy.),
Procurement, BESCOM.